

Connecting Rockwell (Allen-Bradley) PLC

Controllogix 5000 Series - DF1 Serial

Connection Method

RS-232C Connection

Type	Connection Method	Distance
Creating Cable	GP Unit (Dsub25p Male)	Within 15m



- * Connect the shield to the GP's FG terminal.
- * If a communication cable is used, it must be connected to the SG terminal and COMMON terminal.

Recommended Products

Connector/ Cover for GP	Dsub25 pin Plug	XM2A-2501	<OMRON Co.>
	Cover for Dsub25 pin	XM2S-2511	<OMRON Co.>
	Jack Screw	XM2Z-0071	<OMRON Co.>
Cable	CO-MA-VV-SB5P × 28AWG <Hitachi Cable Ltd.>		
Setscrew	Metric Coarse Screw Threads : M2.6 × 0.45		