

Device/PLC Connection Manuals



About the Device/PLC Connection Manuals

Prior to reading these manuals and setting up your device, be sure to read the "Important: Prior to reading the Device/PLC Connection manual" information. Also, be sure to download the "Preface for Trademark Rights, List of Units Supported, How to Read Manuals and Documentation Conventions" PDF file. Furthermore, be sure to keep all manual-related data in a safe, easy-to-find location.

A

Hitachi Industrial Equipment System

A.1

Maximum Number of Consecutive Device Address

The following lists the maximum number of consecutive addresses that can be read by each PLC. Refer to these tables to utilize *Block Transfer*.

When the device is setup using the methods below, the Data Communication Speed declines by the number of times the device is read.



Note:

- When consecutive addresses exceed the maximum data number range
- When an address is designated for *division*
- When device types are different

To speed up data communication, plan the tag layout in screen units, as consecutive devices. (Includes the Alarm and Trend screens.)

■ PLCs

<HIDIC H (HIZAC H) Series>

Device	Maximum No. of Consecutive Address	Device	Maximum No. of Consecutive Address
External Input X	60 Words	Watchdog Timer WD	60 Words
External Output Y		Monostable Timer MS	
Remote Input Relay X		Add Timer TMR	
Remote Output Relay Y		Up Counter CU	
Internal Output R		Ring Counter RCU	
First CPU Link L		Up/Down Counter CT	
Second CPU Link L		Word Internal Output WR	
Data Area M		Timer/Counter Elapsed Value TC	
On-Delay Timer TD		Network Link Area WN	
Single Shot Timer SS			

◆ Ethernet Communication

<HIDIC H Series>

Device	Maximum No. of consecutive device addresses read
External Input	120 Words
External Output	
Remote Input Relay	
Remote Output Relay	
Internal Output	
First CPU Link	
Second CPU Link	
Data Area	
Timer/Counter (Elapsed Value)	
Word Internal Output	
Network Link Area	

A.2**Device Codes and Address Codes**

Device codes and address codes are used to specify indirect addresses for the E-tags or K-tags.

The word addresses of data to be displayed are coded and stored in the word address specified by the E-tags and K-tags. (Code storage is done either by the PLC, or with T-tag and K-tags)

■ **PLCs**

<HIDIC H (HIZAC H) Series>

	Device	Word Address	Device Code (HEX)	Address Code
Bit Address	External Input	WX0000~	X	X
	External Output	WY0000~	X	X
	Remote Input Relay	WX1000~	X	X
	Remote Output Relay	WY1000~	X	X
	First CPU Link	WL000~	C800	Word Address
	Second CPU Link	WL1000~	C800	Word Address
	Data Area	WM000~	9000	Word Address
Word Address	Timer/Counter (Elapsed Value)	TC000~	6000	Word Address
	Word Internal Output	WR0000~	0	Word Address
	Network Link Area	WN0000~	5000	Word Address
	LS Area	LS0000~	4000	Word Address